

# INDIAN STATISTICAL INSTITUTE

## DELHI CENTRE

Gram: STATISTICA, NEW DELHI

7, SJS, SANSANWAL MARG

Phone: 91-11-41493980

Fax: 91-11-41493981

Email: [kalam@isid.ac.in](mailto:kalam@isid.ac.in)



NEAR GUTUB HOTEL  
KATWARIA SARAI

NEW DELHI-110016.

ISID/EMU/Earthbits/2017-18/49

Date:30-01-2018

### Tender Quotation

Name of the work: supply and fixing of new chemical earth bit with copper plate and copper earth wire work and other miscellaneous works are to be carried out in our Institute premises. Kindly inspect the premises where the work has to be carried out and send your **sealed quotations** to reach us **on or before 15.01.2018**. Tender will be received up to **03.00 pm** by The **Officer on Special Duty**, Indian Statistical Institute Delhi centre and will be opened on the same day at **03.30 PM**. The items for which rates are to be quoted are given in the enclosed statement. The Institute reserves the right to reject any or all the quotations or to allot parts of the work to different agencies without assigning any reason.

S.No	Description of material	Qty	Unit	Rate in Rs	Amount in Rs
1.	SITC of 3 meter ashlok copper chemical earth plate. <b>Technical specification:</b> Copper plated, Outer electrode dia 2 inch, inner electrode 1.5 inch, Terminal size 32 x 6 x 65 mm, Terminal hole 12 mm. Copper coating 100 microns. Pipe inner filed with anti corrosive crystalline mixture. Code IS 3043 : 1987	4	nos		
2.	Earthing with copper earth plate 600mm x 600mm x 6mm thick including accessories, and providing masonry enclosure with cover plate having locking arrangements and watering pipe of 2.7 meter long etc. with charcoal/coke and salt as required.	2	set		
3.	Providing and fixing of 25 mm x 5 mm copper strip in 40 mm dia GI pipe from earth electrode including connection with brass nut,	45	mtrs		

	bolt, spring washers excavation and refiling as required.				
4.	Supply and laying of 16 sqmm FRLS PVC insulated single core copper conductor medium class PVC conduit as required.	90	mtrs		
5.	Providing and fixing of 25 mm x 5 mm G.I strip in 40 mm dia GI pipe from earth electrode including connection with brass nut, bolt, spring washers excavation and refiling as required.	10	mtrs		
				<b>Total Rs.</b>	

*K. S. Arora*  
30/1/2018  
Officer on Special- Duty

ISI Delhi Center

**Terms and conditions:**

- 1) The work shall be carried out as per CPWD norms.
- 2) The work shall be carried out under the supervision of the Engineering In-Charge (Electrical).
- 3) The material shall be got approved before use on work.
- 4) The waste should be removed after completion of works.
- 5) Contractor shall be furnished the GSTIN & PAN numbers, without GSTIN & PAN numbers Quotation will be not considered.
- 6) Without Signature quotation will be not considered.

**Copy to:** ISI Website/ISI notice board.