


INDIAN STATISTICAL INSTITUTE

DELHI CENTRE

Gram: STATISTICA, NEW DELHI



7, SJS, SANSANWAL MARG

Phone: 91-11-41493980

Fax: 91-11-41493981

Email: kalam@isid.ac.in

NEAR QUTUB HOTEL
KATWARIA SARAI

NEW DELHI-110016.

Ref; ISID/EMU/Re wiring/Qtrs/2016-17/10

Date:13-07-2016

Tender Quotation

Name of the work: Re-wiring of B-11 flat electrical works are to be carried out in our Institute premises. Kindly inspect the premises where the work has to be carried out and send your **sealed quotations** to reach us **on or before 22.07.2016**. Tender will be received up to **03.00 pm** by The Officer on Special Duty, Indian Statistical Institute Delhi centre and will be opened on the same day at **03.30 PM**. The items for which rates are to be quoted are given in the enclosed statement. The Institute reserves the right to reject any or all the quotations or to allot parts of the work to different agencies without assigning any reason.

S. No	Description of work	Qty	Unit	Rate	Amount
1	Point wiring				
	Wiring fan point/light point/exhaust fan point/call bell point with 1.5 sqmm FRLS PVC insulated copper conductor single core cable in surface/recessed PVC conduit, with modular switch, modular plate, suitable size GI box and earthing the point with Wiring fan point/light point/exhaust fan point/call bell point with 1.5 sqmm FRLS PVC insulated copper conductor single core cable. as required. (Polycab/ Finolex/ Havells)				
a	Group C	15	Point		
2	Point Re-wiring				
	Wiring fan point/light point/exhaust fan point/call bell point with 1.5 sqmm FRLS PVC insulated copper conductor single core cable and 1.5 sqmm FRLS PVC insulated copper conductor single core cable as earth wire in existing surface/recessed steel conduit including dismantling as required. (Polycab/ Finolex/ Havells)				
a	Group C	10	Point		
3	Twin control point wiring in PVC conduit, with modular type switch				

	Wiring for twin control fan point/light point/exhaust fan point/call bell point with 1.5 sqmm FRLS PVC insulated copper conductor single core cable in surface/recessed PVC conduit, with modular switch, modular plate, suitable size GI box and earthing the point with Wiring fan point/light point/exhaust fan point/call bell point with 1.5 sqmm FRLS PVC insulated copper conductor single core cable. as required. (Polycab/ Finolex/ Havells)				
a	Group C	2	Point		
4	Circuit/sub-main wiring in PVC conduit				
	Wiring for circuit/sub-main wiring along with earth wire with the following size of PVC insulated copper conductor, single core cable in surface /recessed PVC conduit as required. (Polycab/ Finolex/ Havells)				
a	4x10 sqmm +2x 10 sqmm earth wire (for sub main)	50	mtrs		
5	Wiring in existing conduit				
	Supply and drawing following size FRLS PVC insulated copper conductor, single core cable in surface /recessed PVC conduit as required. (Polycab/ Finolex/ Havells)				
a	3X2.5 sqmm copper wire (for circuit wiring)	85	mtrs		
b	3X4 sqmm copper wire (for power wiring)	175	mtrs		
6	Supply and fixing of PVC conduit				
	Supply and fixing of following size of medium class PVC conduit along with accessories in surface /recess Including cutting the wall and making good the same in case of recessed conduit as required. IS brand				
a	20 mm	50	mtrs		
b	25mm	65	mtrs		
7	S/F modular boxes, base & cover plate				
	The removing of existing switch board and Supply and fixing of following size/ modules, GI box along with modular base & cover plate for modular switches in recess etc as required.				
a	(Anchor Roma/MK/legrand),8 Module(125mm X 125 mm)	4	nos		
b	(Anchor Roma/MK/legrand),6 Module(200 MM x 75 mm)	8	nos		
c	(Anchor Roma/MK/legrand)4 Module (125 mm X 75mm)	5	nos		
d	(Anchor Roma/MK/legrand),3 Module (100 mm X 75mm)	15	nos		
e	(Anchor Roma/MK/legrand), 1 or 2 Module (100 mm X 75mm)	6	nos		
8	S/F light plug point modular type accessories				